

		HEATING CAPACITIES							COOLING CAPACITIES								
Hauteur	Largueur	Δ T	Output with filter Measured by WSP Lab						Δ T	Max Humidity ratio at 28°C	Output with filter measured by WSP LAB						
			Output with filter Estimated								Output with filter estimated						
			Static	V1 14V	V2 18V	V3 24V	Pente Statique	Pente dynamique			V1 14V	V2 18V	V3 24V	Pente dynamique	Masse a vide (Kg)	Contenance en eau (l)	
1500	8 Elements (592 mm)	Δ T 20	313	767	937	1126	1,284	0,983	Δ T 8	55%	303	381	462	1,040	41,60	8,30	
		Δ T 30	527	1143	1395	1677			Δ T 10	50%	382	481	583				
		Δ T 40	763	1516	1851	2225			Δ T 12	40%	462	581	705				
		Δ T 50	1016	1888	2305	2771			Δ T 14	35%	542	683	827				
1500	10 Elements (740 mm)	Δ T 20	392	799	967	1163	1,284	1,005	Δ T 8	55%	306	397	481	1,046	47,50	10,20	
		Δ T 30	659	1201	1453	1748			Δ T 10	50%	387	502	608				
		Δ T 40	954	1604	1940	2334			Δ T 12	40%	468	607	736				
		Δ T 50	1270	2007	2427	2920			Δ T 14	35%	550	714	864				
1800	8 Elements (592 mm)	Δ T 20	367	984	1214	1461	1,286	0,971	Δ T 8	55%	387	506	619	1,063	49,30	9,80	
		Δ T 30	618	1459	1799	2166			Δ T 10	50%	491	642	785				
		Δ T 40	895	1929	2379	2864			Δ T 12	40%	596	779	953				
		Δ T 50	1192	2396	2955	3557			Δ T 14	35%	702	918	1123				
1800	10 Elements (740 mm)	Δ T 20	459	1032	1248	1493	1,286	0,983	Δ T 8	55%	402	530	652	1,053	56,00	11,90	
		Δ T 30	772	1537	1858	2224			Δ T 10	50%	509	671	825				
		Δ T 40	1118	2040	2465	2951			Δ T 12	40%	617	813	1000				
		Δ T 50	1490	2540	3070	3674			Δ T 14	35%	725	956	1176				
2000	8 Elements (592 mm)	Δ T 20	398	1111	1375	1677	1,295	0,960	Δ T 8	55%	477	614	755	1,073	54,40	10,60	
		Δ T 30	673	1640	2029	2476			Δ T 10	50%	606	780	959				
		Δ T 40	977	2161	2675	3264			Δ T 12	40%	737	949	1166				
		Δ T 50	1304	2678	3314	4044			Δ T 14	35%	869	1119	1376				
2000	10 Elements (740 mm)	Δ T 20	498	1154	1408	1689	1,295	0,984	Δ T 8	55%	481	621	787	1,077	61,80	13,20	
		Δ T 30	841	1720	2099	2518			Δ T 10	50%	612	790	1001				
		Δ T 40	1221	2283	2786	3342			Δ T 12	40%	745	961	1218				
		Δ T 50	1630	2844	3470	4163			Δ T 14	35%	879	1135	1438				

Exponents - Heating Capacities			
static	V1	V2	V3
1,2883	0,9810	0,9810	0,9810

Exponents - Cooling capacities			
static	V1	V2	V3
-	1,0587	1,0587	1,0587

Donnée techniques en rafraichissement				
	Taux hygro	T° Entrée	T° Sortie	T° ambiante
Δ T 8	55%	19	21	28
Δ T 10	50%	17	19	28
Δ T 12	40%	15	17	28
Δ T 14	35%	13	15	28